

## ***Instructions for completing the NE&C CHILLER Rebate Worksheet***

### **Requirements:**

1. This rebate is available only for comfort cooling applications operating for min. 800 equivalent full load hours (EFLH) or 1500 run hours. Process chillers or chillers equipped w/ variable speed drives may be evaluated as a custom rebate.
2. Chiller equipment efficiency criteria are based on ARI Standard 550/590-98 at ARI standard conditions (see note 6) using a non-CFC refrigerant. Attach copy of manufacturer's performance sheet showing both Full Load (FL) and Integrated Part Load Value (IPLV) efficiencies (kW/ton). Air cooled chiller efficiencies shall include condenser fan energy consumption. Tons should be ARI net capacity, not gross capacity. Rebates for chillers shall be calculated using FL (Full Load) and IPLV (Integrated Part Load Value) efficiency ratings.
3. The total rebate (I) for air cooled chiller projects with efficiencies based on EER is calculated as follows:  
F = base rebate (C x E) and H = performance rebate (using either FL or IPLV EER): (D-B) x 10 x C x G  
(performance rebate is for each 0.1 EER point above minimum criteria and may not exceed twice the base rebate)
4. The total rebate (I) for water cooled chiller projects with efficiencies based on kW / ton is calculated as follows:  
F = base rebate (C x E) and H = performance rebate (using FL or IPLV kW/ ton): ): (B-D) x 100 x C x G  
(performance rebate is for each 0.01 KW/ton below maximum criteria and may not exceed twice the base rebate)
5. All water-cooled chillers shall incorporate condenser water reset strategy.
6. ARI Chiller standard 550/590-98 conditions are as follows:  
44° F leaving chiller water,  
2.4 GPM / ton,  
95° F entering condenser air temperature (air cooled only),  
85° F entering condenser water temperature (water cooled only),  
3.0 GPM / ton condenser water flow rate (water cooled only)
7. Chillers with VFD's shall have a minimum 3% impedance reactor in its AC power input connection.
8. Chiller equipment using chlorofluorocarbons (CFC's) as a refrigerant is not eligible for a rebate. This includes the following refrigerant: CFC-11, CFC-12, and CFC-115 (R502).
9. The rebate offer is not valid unless signed and dated by the Utility Representative. The Customer accepts the Utilities rebate offer and agrees to the Terms and Conditions of the Utility by signing in the pre-approval offer block.
10. The Chiller Application must be completed and the rebate approved prior to purchasing or installing the equipment.
11. Invoices will be required for payment of rebates.
12. The rebate, in conjunction with all other sources of funding, cannot exceed the total project cost.

### **Pre-Installation:**

1. Review the rebate eligibility requirements.
2. Review the proposed equipment specifications to confirm it meets the minimum efficiency requirements. Chillers must have both Full Load (FL) and Integrated Part Load Value (IPLV) efficiencies.
3. Provide to the utility representative the manufacturer's equipment specifications and record the following information on the worksheet: manufacturer/model number, unit size, unit efficiency, chiller tons and Full Load (FL) and Integrated Part Load Value (IPLV) efficiencies (kW/ton or EER).
4. Calculate the appropriate rebate in the following examples:

# 2011-2012 Chiller Rebate

## Examples of how to calculate chiller rebates:

Eligibility Requirements		Proposed Equipment		Rebates				
Unit Size ARI Net Tons (A)	Minimum Performance Requirements, FL or IPLV (B)	Net Tons (C)	Proposed Efficiency (D)	Base Rebate (per ton) (E)	Base Rebate Total (F)	Performance Rebate per ton (Max of 2 times base rebate) (G)	Performance Rebate Total (H)	Total Rebate (F+H) (I)
<b>Air Cooled Chillers</b>								
< 150 tons	EER: FL: 10.52 IPLV: 13.75	<u>125</u>	FL: 9.8 IPLV: 14.2	\$25.00	<u>\$3,125</u>	\$4.00	<u>\$2,250</u>	<u>\$5,375</u>
<b>Water Cooled Chillers-Centrifugal</b>								
≥ 150 and < 300 tons	kW/ton: FL: 0.518 IPLV: 0.360	<u>275</u>	kW/ton: FL: 0.580 IPLV: 0.335	\$17.00	<u>\$4,675</u>	\$3.00	\$2,063	<u>\$6,738</u>

### Ex 1: rebate calculation for a 100 ton air cooled chiller unit with EER= 9.8 (FL) and EER = 14.2 (IPLV)

Unit does not meet Full Load minimum requirement (however, it does meet the IEEC 2009 Code) and meets IPLV minimum requirement so the unit qualifies for a rebate.

Base rebate: (CXE) + Performance rebate: (D-B) / 0.1 x C x G

Base rebate = 125 x \$25 = \$3,125

Performance rebate (using IPLV kW/ton values) = (14.2-13.75) x 10 x \$4 = \$18/ton, rebate is

125\* \$18 = \$2,250 which is less than the maximum of 2 times the base rebate

Total rebate (I) = \$3,125 + \$2,250 = **\$5,375**

### Ex 2: rebate calculation for a 275 ton water cooled chiller unit with a FL kW/ton of 0.580 and IPLV kW/ton of 0.335

Unit does not meet Full Load minimum requirement (however, it does meet the IEEC 2009 Code) and meets IPLV minimum requirement so the unit qualifies for a rebate.

Base rebate: (CXE) + Performance rebate: (B-D) / 0.01 x C x G

Base rebate = 275 x \$17 = \$4,675

Performance rebate (using IPLV kW/ton values) = (0.360-0.335) x 100 x \$3 = \$7.50/ton, rebate is

275 \*\$7.50 = \$2,063 which is less the maximum rebate of than 2 times the base rebate.

Total rebate (using IPLV kW/ton values), (I) = \$4,675 + \$2,063 = **\$6,738**

## Post-Installation:

### Utility Representative must verify that:

1. The Chiller has been installed and operable.
2. The installed chiller matches the Chiller Rebate Application information. If the equipment has changed from what was approved for the initial rebate offer, the actual equipment specifications must be submitted and reviewed by the utility to verify compliance with technical requirements and approved before a rebate is considered.
3. The invoice or proof of payment has been submitted.
4. The Utility Representative & Customer have signed & dated the post installation inspection block on the rebate form.